



25th November, 2024

CLARIFICATION/ADDENDUM “SET 2”

**TENDER NO. KRA/HQS/NCB - 013/2024-2025: PROVISION OF SUPPORT AND
MAINTENANCE SERVICES FOR DATA CENTRE SYSTEM AND SWITCH
GEARS FOR A PERIOD OF TWO (2) YEARS**

Kenya Revenue Authority wishes to inform prospective bidders of the amendments detailed below for the referenced tender.

No	Query	KRA Response/ Clarification
1.	<p>SECTION III -EVALUATION AND QUALIFICATION CRITERIA</p> <p>PART A. PRELIMINARY/ MANDATORY EVALUATION CRITERIA, CRITERIA NO.7 i.e.</p> <p>Original Equipment Manufacturer’s Authorized Service Provider Certificate for the equipment bided for. Third Party arrangements shall not be accepted.</p> <p>Does this mean we are only allowed to get the certificate from the manufacturer not the local distributor in the country?</p>	<p>Bidders are advised that; The MAF can also be from a Local Authorised Dealer for the Electrical Equipment and Boards installed at KRA Data Centre.</p>
2.	<p>SECTION III -EVALUATION AND QUALIFICATION CRITERIA</p> <p>PART C. TECHNICAL EVALUATION CRITERIA item no.4 where both the intrusive and non-intrusive checks are clearly defined. We require clarification on the number of times when the intrusive checks should be done in a year? For the non-intrusive checks, it is clearly defined to be 3 times every year</p>	<p>Bidders are advised that; The PM checks are supposed to be carried out 4 times a year as stated on item no. 1 (page 33 specifications table), where either the intrusive or non-intrusive check can be performed depending on the suitability and appropriateness of the procedure of the component under examination.</p>
3	<p>1. Kindly provide more clarity on the specifications of the items listed on the spare list i.e current rating and part no as shown in the document</p>	<p>1. Bidders are advised that the price schedule has been expunged and replaced with a NEW PRICE SCHEDULE marked as ANNEX I herein attached.</p>

	<p>2. We request for an extension of the bid submission date for us to respond to the bid appropriately. There are some site prerequisite that need to be captured during site survey that will help in preparation of the proposal, with the site visit being 2 days before submission this will be a challenge</p>	<p>2. Prospective bidders are advised that they can visit the site any day before the revised tender closing date i.e 4th December, 2024.</p>
4	<p>1. We require more clarification on no of sub-boards in the datacentre white space with their incomer power rating including the number of 3 phase bus bars feeding the rack PDU, this will enable us to have a better understanding of the power supply infrastructure at the white space.</p> <p>2. We also require more clarifications on the extent of maintenance scope whether the rack PDUs are part of the scope?</p>	<p>Prospective bidders are advised that;</p> <ol style="list-style-type: none"> 1. Two (2) Sub-boards in the white space 2. Two(2) riser boards feeding eight (8) 3 Phase bus bars 3. The bidders are advised to capture/confirm these during site survey visit as insisted by KRA. 4. The scope of maintenance includes the rack PDU.
5	<p>New Tender closing / Opening Date and time</p>	<p>The new tender closing/ opening date is Wednesday 4th December, 2024 at 11.00am – Times Tower</p>
<ul style="list-style-type: none"> • Bidders are advised to align their tender securities to be valid for three hundred and sixty five (365) days from the revised tender closing date i.e valid until 3rd December, 2025. 		

The clarification forms part of the bidding document and is binding to the bidder. All other terms and conditions of the tender remain the same. You are therefore required to immediately acknowledge the receipt of this addendum.



Martha Wakio Njuguna

FOR: DEPUTY COMMISSIONER - SUPPLY CHAIN MANAGEMENT

ANNEX 1
NEW PRICE SCHEDULE

PROVISION OF SUPPORT AND MAINTENANCE SUPPORT AND MAINTENANCE SERVICES FOR KRA DATA CENTER (ELECTRICAL SYSTEMS AND ELECTRICAL SWITCHGEARS INFRASTRUCTURE) FOR A PERIOD OF TWO (2) YEARS (PRICES SHOULD BE INCLUSIVE OF TAXES)

Description	Year 1 (KES)	Year 2 (KES)
SUPPORT AND MAINTENANCE SERVICES FOR ELECTRICAL SYSTEMS AND SWITCHGEARS INFRASTRUCTURE	A	B
TOTAL		
GRAND TOTAL (A+B) FOR TWO (2) YEARS INCL.OF TAXES [TO BE CARRIED TO FORM OF TENDER]		

Provision of Spare Parts on a need basis at the indicated unit rates below (up to a maximum spend of **KES. 3,000,000.00 per year)**

PARTs DETAILS

	Item	Model/Description	Rating	Unit Cost(Inclusive of Applicable taxes)
1.		AR2165	4pole-1600A	
2.	TERASAKI ACBs	AR2165	3pole-1600A	
3.		S250-NJ	250A	
4.	TERASAKI	S630-NE	630A	
5.	MCCBs	S160-SJ	160A	
6.		S800-CJ	800A	
7.		S160-SJ	125A	
8.	Bus Bars GRAZIAT10&CO	J series	160A	
9.		chint -CJ19-6321	63A	



10.	Contractors	lovato -Bf3800A	56A	
11.		lovato -Bf0040A	40A	
12.	Lovato System Monitors	DMG-900	Input voltage	
13.		DMG-800		
14.		DMG-700	10v---690v	
15.		DME-D310T2	Input current 0.1----5A	
16.	Power factor controller	Lovato DCRL8		
17.	LED Display light	Lovato 8LP2 T1LM6P		
18.	AVR Monitor boards	IREM 78810040		
19.	Automatic change over switch	Lovato GEX694C	230vac- 50 60hz	
20.		GEX692	230vac- 50 60hz	
21.		Gave YL563A101 4 pole	160A	
22.	Power Capacitors	Ener Lux 440v	14Kvar SE65231DA	
23.			28Kvar SE65465AB	
24.	Power reactors	Ener Lux 4000v	25kvar RA4025189	
25.	TERASAKI motor operator	T2MC40	Uc: 100-240 VAC	
26.	On delay timer	Lovato	TMP 16VA/0.9W max (110--- 240VAc)	
27.	Relay	5R2240VADC1C0		

28.	TEE/SPS MCBs	Single pole	6A—32A, 10A, 63A	
29.		Double pole	100A— 125A, 63A, 32A	
30.		Triple pole	32A, 63A, 63A, 100A	
31.	Phase/Voltage controller	GIC DPT, DIM, RAIL	IPH, 3PH- 4wire 240VAc 47-63HZ	
32.		Lovato PMV50A575	380--- 575VAC 50/60HZ	
33.	Industrial Sockets	3PH-32A,16A, 1PH-32A,16A		
34.	Power Distribution Units (PDU)			

1. All prices quoted must be inclusive all applicable taxes in Kenya
2. Affix Company Stamp on this page.

Tender's Signature: _____

Date: _____

